



BRUHAT BANGALORE MAHANAGARA PALIKE

NO.DHO(Bom)/PR/189/2022-23

OFFICE OF THE DEPUTY HEALTH OFFICER
BOMMANAHALLI ZONE
BRUHAT BANGALORE MAHANAGARA PALIKE.
DATE: 18.03.2023

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team head by VEERESH KUMAR, Medical Officer of Health from BBMP Health Department inspected NATIONAL PUBLIC SCHOOL, #47/1, BASAVANAPURA, GOTTIGERE POST, BANNERGATTA ROAD, BENGALURU- 560083 on 20-03-2023, checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T Government.

The above is valid for a period of 19th March 2024.

**THOMAS
PLATHOTA
THIL JOHN**

Digitally signed by THOMAS PLATHOTATHIL JOHN
DN: c=IN, postalCode=560038, st=KARNATAKA, street=BANGALORE, l=BANGALORE, o=Personal, serialNumber=24a07d0a6026bc96d5e0d5cc7251a7d17422fac42b7c48d9e7852a08e4de2b27, pseudonym=9ed68c227b094746ab7fe8097bc33d93, 2.5.4.20=d2f0aeb1ed45c43949511ac53b9fba1ca21d32e6fe003b623b3778033d4ea31d, email=DRTHOMAS@TJOHNGROUP.COM, cn=THOMAS PLATHOTATHIL JOHN
Date: 2023.06.10 12:34:16 +05'30'

Deputy Health Officer
Bommanahalli Zone
BBMP, Bangalore

To
NATIONAL PUBLIC SCHOOL
#47/1, BASAVANAPURA,
GOTTIGERE POST,
BANNERGHATTA ROAD,
BANGALORE- 560083.



BANGALORE TEST HOUSE

65, 20th Main, Marenahalli,
Vijayanagar, Bangalore - 560 040.

Ph.: 23356415, 23388895, 23502689 Fax : 080-23385979
e-mail : testhouse@satyam.net.in website : www.bthindia.com

TEST CERTIFICATE

1 of 1

National Public School
#47, Basavanapura, Gottigere Post,
Bannerghatta Road
Bengaluru - 560 083

Supplementary
Report No : 3866
Date of Report : 10.03.2023
Reference No : Letter
Dated : 08.03.2023
Date of Receipt : 08.03.2023
Job Order No : ED/2023/03/0763

Sample Particulars: One sample of Water was received.

<u>TESTS</u>	<u>RESULTS</u>	<u>ACCEPTABLE LIMITS AS PER IS: 10500 – 1991 (Amd.2)</u>	<u>PROTOCOL</u>
Description	: Colourless and clear transparent liquid filled in a plastic can.		
<u>MICROBIOLOGICAL TESTS :</u>			
Coliform Organisms /100 ml	: Less than 1	: Less than 1	: IS:1622-1981
E.coli Bacteria/100ml	: Absent	: Absent	: IS:1622-1981

Remarks : The sample conforms to IS:10500-1991 for drinking water
with respect to chemical & Microbiological Requirements.

AUTHORISED SIGNATORY

- NOTE: 1. The result listed refer only to the tested samples & applicable parameters. Endorsement of products is neither inferred nor implied.
2. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified.
3. This report is not to be reproduced wholly or in part & cannot be used as an evidence in the Court of law & should not be used in any advertising media without our special permission in writing..
4. Sample (s) not drawn by us unless otherwise stated.
5. Total liability of our laboratory is limited to the invoiced amount. Any dispute arising out of this report is subject to Bangalore Jurisdiction only.



BANGALORE TEST HOUSE

65, 20th Main, Marenahalli,
Vijayanagar, Bangalore - 560 040.

Ph.: 23356415, 23388895, 23502689 Fax : 080-23385979
e-mail : testhouse@satyam.net.in website : www.bthindia.com

TEST CERTIFICATE

National Public School
#47, Basavanapura, Gottigere Post,
Bannerghatta Road
Bengaluru - 560 083

Part Analysis
Report No : 3866
Date of Report : 10.03.2023
Reference No : Letter
Dated : 08.03.2023
Date of Receipt : 08.03.2023
Job Order No : ED/2023/03/0763

Sample Particulars: One sample of Water was received.

TESTS	RESULTS	MAXIMUM ACCEPTABLE LIMITS AS PER IS: 10500 -1991 (Amd.2)	MAXIMUM PERMISSIBLE LIMITS IN THE ABSENCE OF ALTERNATE SOURCE AS PER IS: 10500-1991 (Amd.2)	PROTOCOL
Colour, True colour units	: < 2.0	: 5	: 25	: IS: 3025 (P 4)
Odour	: Unobjectionable	: Unobjectionable	: -	: IS: 3025 (P 5)
Taste	: Agreeable	: Agreeable	: -	: IS: 3025 (P 8)
Turbidity, NTU	: 0.4	: 5	: 10	: IS: 3025 (P 10)
pH	: 7.88	: 6.50 to 8.50	: No relaxation	: IS: 3025 (P 11)
Chlorides, as Cl, mg/L	: 60.0	: 250	: 1000	: IS: 3025 (P 32)
Total Hardness as CaCO ₃ , mg/L	: 239.0	: 300	: 600	: IS: 3025 (P 21)
Calcium, as Ca, mg/L	: 56.1	: 75	: 200	: IS: 3025 (P 40)
Magnesium, as Mg, mg/L	: 24.1	: 30	: 100	: IS: 3025 (P 46)
Total Dissolved solids, mg/L	: 460.0	: 500	: 2000	: IS: 3025 (P 16)
Sulphates, as SO ₄ , mg/L	: 38.6	: 200	: 400	: IS: 3025 (P 24)
Copper, as Cu, mg/L	: < 0.05	: 0.05	: 1.5	: IS: 3025 (P 42)
Iron, as Fe, mg/L	: 0.05	: 0.30	: 1.0	: IS: 3025 (P 53)
Manganese, as Mn, mg/L	: < 0.1	: 0.1	: 0.3	: 35 OF IS: 3025
Nitrates, as NO ₃ , mg/L	: 2.5	: 45	: No relaxation	: IS: 3025 (P 34)
Fluorides, as F, mg/L	: 0.2	: 1.0	: 1.5	: 23 OF IS: 3025
Phenolic Compounds, as C ₆ H ₅ OH, mg/L	: Absent	: 0.001	: 0.002	: IS: 3025 (P 43)
Mercury, as Hg, mg/L	: < 0.001	: 0.001	: No relaxation	: IS: 3025 (P 48)
Cadmium, as Cd, mg/L	: < 0.01	: 0.01	: No relaxation	: IS: 3025 (P 41)
Selenium, as Se, mg/L	: < 0.01	: 0.01	: No relaxation	: IS: 3025 (P 56)
Arsenic, as As, mg/L	: < 0.01	: 0.01	: No relaxation	: IS: 3025 (P 37)
Cyanide, as CN, mg/L	: Absent	: 0.05	: No relaxation	: APHA
Lead, as Pb, mg/L	: < 0.01	: 0.05	: No relaxation	: IS: 3025 (P 47)
Zinc, as Zn, mg/L	: 0.02	: 5	: 15	: IS: 3025 (P 49)
Anionic Detergents as MBAS, mg/L	: < 0.2	: 0.20	: 1.0	: ANNEX K OF IS:13428
Chromium, as Cr ⁶⁺ , mg/L	: < 0.01	: 0.05	: No relaxation	: IS: 3025 (P 52)
Residual Free Chlorine, mg/L	: 0.05	: Min 0.20	: -	: IS: 3025 (P 26)
Alkalinity, as CaCO ₃ , mg/L	: 243.0	: 200	: 600	: IS: 3025 (P 23)
Aluminium, as Al, mg/L	: 0.2	: 0.03	: 0.2	: IS: 3025 (P 55)
Boron, as B, mg/L	: < 0.1	: 1.00	: 5.0	: APHA

A. R. Rakesh
AUTHORISED SIGNATORY

- NOTE: 1. The result listed refer only to the tested samples & applicable parameters. Endorsement of products is neither inferred nor implied.
2. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified.
3. This report is not to be reproduced wholly or in part & cannot be used as an evidence in the Court of law & should not be used in any advertising media without our special permission in writing..
4. Sample (s) not drawn by us unless otherwise stated.
5. Total liability of our laboratory is limited to the invoiced amount. Any dispute arising out of this report is subject to Bangalore Jurisdiction only.

Registration No: KSPCB/CEL/EMP/02



KARNATAKA STATE POLLUTION CONTROL BOARD

Parisara Bhavan, #49, 4th & 5th Floor, Church Street
Bangalore - 560001

CERTIFICATE OF EMPANELMENT

This is to certify that M/s BANGALORE TEST HOUSE

Located at BANGALORE TEST HOUSE, 65, 20TH MAIN, MARENAHALLI
VIJAYANAGAR, BANGALORE-560040.

is empanelled by Karnataka State Pollution Control Board to undertake analysis and reporting
of test results of Environmental Samples.

This is valid for a period of five years and subject to conditions over leaf.

Issue Date : 1st Aug 2019

Expiry Date : 31st Jul 2024

Chief Scientific Officer

Chairman

Library & Laboratory Committee
KSPCB



FORM III [See Regulation 7(1) (D) (d)]

BUREAU OF INDIAN STANDARDS
LICENCE FOR THE QUALITY MANAGEMENT SYSTEMS CERTIFICATION

Licence No. *MSC/L - 6000841.3*

1. By virtue of the power conferred on it by, the Bureau of Indian Standards Act, 1986 (63 of 1986), the Bureau hereby grants to *M/s. Bangalore Test House, No. 65, 20th Main, Marenahalli, Vijayanagar, Bangalore - 560 040 Karnataka* (hereinafter called the Licensee) the right and licence to be listed in the Bureau's register(s) of Licensees of Quality Management Systems Certification in respect of the products or processes particularly described in the schedule hereto, bearing the same number as this licence. Such Products or processes shall be manufactured by the Licensee at only the address(es) given above, and under the Quality Management Systems in accordance with **ISO 9001:2015**
2. The Licence is granted subject to the relevant provisions of the above Act and the rules and regulations made thereunder governing the licences referred to above, and the Licensee hereby covenants with the Bureau duly to observe with the said Rules and Regulations.
3. This licence shall be valid from **15 December 2019 to 14 December 2024** and may be renewed as prescribed in the Regulations.

Signed, Sealed and Dated this *Fifteenth day of December, Two thousand and Nineteen*

DEPUTY DIRECTOR GENERAL (SOUTH)
for BUREAU OF INDIAN STANDARDS

Schedule to Licence No. *MSC/L - 6000841.3*

Issued to *M/s. Bangalore Test House, No. 65, 20th Main, Marenahalli, Vijayanagar, Bangalore - 560 040 Karnataka*

SCHEDULE

Products/processes with respect to which the firm has been granted the licence for Management Systems Certification:

"Providing Laboratory Services for Chemical Analysis and Microbiology Analysis of Water, Air & Effluents, Drugs and Foods,, Soil, Chemicals, Pesticides, Cement, Petroleum Products, Excluding Design and Development Activities"

DEPUTY DIRECTOR GENERAL (SOUTH)
for BUREAU OF INDIAN STANDARDS